



City of Morden
Planning & Engineering
100-195 Stephen Street
Morden, MB R6M 1V3
[tel] 204-822-4434
[fax] 204-822-6494

Addendum 1

Tender 1202: Tabor Home Infrastructure. Street Base

The City of Morden wishes to make the following clarifications to the contract:

1. Please note that the **C-Base depth is 300mm** and not 450mm as shown on Plan 1.

Sincerely,

A handwritten signature in blue ink, appearing to read "Dave Haines".

Dave Haines, P. Eng.