



Addendum 1

Tender 1206: Pembina Connection Lift Station Relocation

The City of Morden wishes to make the following clarifications and amendments to the contract:

1. To Section 0200 *Schedule of Quantities and Prices*:
 - 1.1 **Item 10**: The price for this item includes everything indicated in Section 0400 *General Conditions and Specifications* plus the installation of the Concrete Slab as per the Plans. Please include the cost of concrete and all other materials necessary to install the Concrete Slab into the Contractor's Price; For the Concrete Slab use reinforcement as follows: one layer of 10M steel bars in both directions with 200mm space. Concrete cover for steel reinforcement shall be 3".
If you wish to propose an alternative to that on the Plans, please do so as a "Contractor's Proposed Amendment", but be sure to include a price for item 10 as requested;
 - 1.2 **Item 11**: The Contractor is not responsible for the relocation of the existing Hydro Pole and must not include the cost of this work into the item price. The City takes care of all expenses required for the relocation. The Hydro Pole will be relocated 6m to the south from the existing position before the excavation is started. The Contractor is still responsible for the protection of existing overhead hydro wires during the construction;
2. The submittal deadline for the Tender has been extended by one week:
From: 11 a.m. on Monday, March 31, 2014
To: **11 a.m. on Monday, April 7, 2014.**

Sincerely,

Tatiana Sinchenko
City of Morden
Engineering Assistant